



# CHESTERFIELD COUNTY WATER AND SEWER SPECIFICATIONS

## THIRD EDITION

### ADDENDUM #2 - LIST OF CHANGES January 26, 2004

## PART I

** PAGE # **	*** CHANGE ***
DS-17	Under #4 – first sentence – <i>changed</i> the word “rodded” to “ <b>restrained</b> ”.

## PART II

** PAGE # **	*** CHANGE ***
iii	<i>Changed</i> Index of Drawings to reflect new details.
FIR-1 (1 of 2)	<i>Changed</i> detail to apply only to non-residential systems.
FIR-1 (2 of 2)	<i>Changed</i> detail to apply only to non-residential systems.
FIR-1B NFPA 13D (1 of 2)	<i>Created</i> new detail that applies to residential fire line systems.
FIR-1B NFPA 13D (2 of 2)	<i>Created</i> new detail that applies to residential fire line systems.
FIR-3 Sht. 1 of 3	<i>Changed</i> reference to “Blowup Detail A” from “see Sht. 2 of 2” to “ <b>see Sht. 3 of 3</b> ”.
MET-6	Made some slight <i>grammatical changes</i> to Note #2.
MET-8	<i>Modified</i> the area to be enclosed inside the vault.

## PART III

** PAGE # **	*** CHANGE ***
BF-4	Second paragraph – <i>added</i> the following sentence – <b>“Failure to sign and return this page will be cause for rejection of bid.”</b>

## PART V

** PAGE # **	*** CHANGE ***
V-1-7	Under G. Tapping Sleeve - #2 – h. – <i>changed</i> 6”-24” to <b>4”-20”</b> ; <i>added</i> <b>“i. Smith-Blair Model 622 MJ (4”-20”)”</b> ; <i>added</i> <b>“J. Mueller H300 (Not to be used on Asbestos Cement Pipe)”</b> .
V-1-10	Under P. Service Saddles - #1 – <i>changed</i> “2025” to <b>“202N”</b> .
V-1-11	Under Q. Pipe restraints - #1 – <i>added</i> <b>“g. SIGMA One-Loc Model SLC”</b> .
V-1-12	Under T. Double Check and Double Detector Check Devices – Ames Co., Inc. - <i>added</i> <b>2000SE – 8”, 3000SE - 8”, 200A Colt Series - Size 2½”-10½”, and 300A Colt Series - Size 2½”-10½”</b> , Conbraco Industries, Inc. – <i>added</i> <b>“Model #4S-100 Size 2½”-6” and 40100 – Size 2½”-10”</b> .
V-1-13 & V-1-14	Under T. Double Check and Double Detector Check Devices – Febco – <i>added</i> <b>Model #40-100, Size 6”-10”</b> ; Watts Regulator Co., - <i>added</i> <b>007 – ½”-3” and 007DCDA – 2”-3”</b> , Zurn Industries, Inc. (Wilkins) – <i>added</i> <b>“Model 350 - Size 2½”-6”, 350 - Size 4”-6”, 350DA – 4”-6”, 450 – 4”-6”, 450DA – 4”-6”, 950 - 2½”-10”, removed DCDA– 3”-6”</b> . Under U. – <i>Changed</i> “Reduced-Pressure Principle Devices” to <b>“Reduced-Pressure Principle Zone Devices”</b> . Under U. – Reduced-Pressure Principle Zone Devices – <i>Changed</i> “Cla-val Co.” device models and numbers to <b>“Conbraco”</b> and <i>added</i> <b>“40200 - 2½”-10””</b> , <i>added</i> new category <b>“Cla-val”</b> with model # <b>“RP-2 - ¾”-1½””</b> .
V-3-1, V-3-15, V-3-16 & V-3-17	<i>Changed</i> “Uponor ETI Company” to <b>“PW Eagle, Inc. (formerly Uponor ETI Company)”</b> .
V-4-7	Under 5. Tapping Sleeves – Fabricated Steel with Mechanical Joint Ends – f. – <i>added</i> <b>“*** Mueller H300 can not be used on A/C and C.I. Pipe.”</b>
V-4-13	Under 9. Water Service Assembly for 5/8” Water Meters – g. Service Saddles – 1) – <i>deleted</i> “corrosion resistant paint or” and <i>added</i> <b>“or nylon”</b> .